

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	Pol				Pol
2	7.8				Pol
3	7.8				Y
4	Pol				Pol
5	7.8				Y
6	7.9				Y
7	7.9				Y
8	Pol				Pol
9	Pol				Pol
10	Pol				Pol
11	Pol				Pol
12	8.0				X
13	8.1				Y
14	Pol				Pol
15	8.2				Y
16	Pol				Pol
17	7.8				Y
18	7.8				Y
19	8.0				Y
20	8.2				Y
21	8.1				Y
22	8.0				Y
23	Pol				Pol
24	Pol				Pol
25	Pol				Pol
26	8.1				Y
27	8.1				Y
28	8.0				Y
29	Pol				Pol
30	7.9				Y
31					Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

County: Douglas Agency: REGION 2

**ENTRY POINT**

**EP-A**

**PWS ID 4101092**

**USFS TILLER RANGER STATION**

Sample period: June 2021  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.4

Print Name: Jonathan Woody

Signature: [Signature]

Date & Phone#: 7-9-21 / 541-643-6137

Send to DWP within 10 days after end of sampling period