

Day	pH	Alk	Phos	Other	Y/N
1	Pol				Pol
2	8.2				Y
3	Pol				Pol
4	Pol				Pol
5	Pol				Pol
6	8.3				Y
7	8.2				Y
8	Pol				Pol
9	Pol				Pol
10	Pol				Pol
11	Pol				Pol
12	7.9				Y
13	8.1				Y
14	7.9				X
15	Pol				Pol
16	8.1				Y
17	8.3				Y
18	8.0				Y
19	Pol				Pol
20	7.8				X
21	7.9				X
22	8.0				X
23	Pol				Pol
24	7.8				Y
25	7.9				Y
26	Pol				Pol
27	8.4				Y
28	8.4				Y
29	Pol				Pol
30	Pol				Pol
31					

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

County: Douglas Agency: REGION 2

**ENTRY POINT**

**EP-A**

**PWS ID 4101092**

**USFS TILLER RANGER STATION**

Sample period: November '21  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH

Print Name: Jonathan Waddy

Signature: [Signature]

Date & Phone#: 12-7-21

Send to DWP within 10 days after end of sampling period