



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	Pol				Pol
2	8.0				Pol
3	POL				Pol
4	POL				Pol
5	POL				Pol
6	Pol				Pol
7	POL				Pol
8	7.9				Y
9	POL				Pol
10	7.9				Y
11	8.3				Y
12	8.3				Y
13	Pol				Pol
14	8.3				Y
15	8.1				Y
16	8.2				Y
17	POL				Y
18	8.2				Y
19	7.8				Y
20	7.8				Y
21	7.8				Y
22	Pol				Pol
23	Pol				Pol
24	Pol				Pol
25	8.4				Y
26	8.5				Y
27	7.9				Y
28	8.4				Y
29	Pol				Pol
30	Pol				Pol
31					

<<Have minimums been met for this day?

County Douglas Agency REGION 2

### ENTRY POINT

EP-A

PWS ID 4101092

USFS TILLER RANGER STATION

Sample period: June '22  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.4

Print Name: Jonathan Woody

Signature: [Signature]

Date & Phone#: 7-10-22 5416436137

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0