

Day	pH	Alk	Phos	Other	Y/N
1	po1				po1
2	po1				po1
3	POL				po1
4	POL				po1
5	8.3				
6	8.2				Y
7	8.2				Y
8	po1				po1
9	po1				po1
10	8.3				Y
11	8.3				Y
12	8.3				Y
13	8.3				Y
14	po1				po1
15	8.3				Y
16	8.1				Y
17	8.2				Y
18	8.3				Y
19	po1				po1
20	po1				po1
21	8.4				Y
22	8.4				Y
23	po1				po1
24	8.3				Y
25	8.3				Y
26	po1				po1
27	po1				po1
28	po1				po1
29	8.2				Y
30	8.3				Y
31					

<<Have minimums been met for this day?

County: Douglas Agency: REGION 2

**ENTRY POINT**

EP-A

PWS ID 4101092

USFS TILLER RANGER STATION

Sample period: Sept 2022  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.4

Print Name: Jonathan Woody

Signature: [Signature]

Date & Phone#: 10-7-22 541-643-6137

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0