

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | 8.3 | | | | Y |
| 2 | 8.2 | | | | Y |
| 3 | 8.2 | | | | Y |
| 4 | Pol | | | | Pol |
| 5 | Pol | | | | Pol |
| 6 | 8.3 | | | | Y |
| 7 | 8.2 | | | | Y |
| 8 | 8.3 | | | | Y |
| 9 | 8.0 | | | | Y |
| 10 | 8.1 | | | | Y |
| 11 | Pol | | | | Pol |
| 12 | Pol | | | | Pol |
| 13 | Pol | | | | Pol |
| 14 | Pol | | | | Pol |
| 15 | 8.3 | | | | X |
| 16 | 8.4 | | | | Y |
| 17 | 8.3 | | | | Y |
| 18 | Pol | | | | Pol |
| 19 | Pol | | | | Pol |
| 20 | Pol | | | | Pol |
| 21 | Pol | | | | Pol |
| 22 | POL | | | | POL |
| 23 | 8.2 | | | | Y |
| 24 | 8.3 | | | | Y |
| 25 | 8.4 | | | | Y |
| 26 | 8.4 | | | | Y |
| 27 | 8.4 | | | | Y |
| 28 | POL | | | | POL |
| 29 | POL | | | | POL |
| 30 | POL | | | | POL |
| 31 | POL | | | | POL |

County: Douglas Agency: REGION 2

<<Have minimums been met for this day?

ENTRY POINT
EP-A
PWS ID 4101092
USFS TILLER RANGER STATION

Sample period: October 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

Print Name: Jonathan Woody

Signature: [Signature]

Date & Phone#: 11-4-2022 / 1246, 541-643 6137

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's