

Day	pH	Alk	Phos	Other	Y/N
1	POL				POL
2	POL				POL
3	POL				POL
4	POL				POL
5	POL				POL
6	POL				POL
7	POL				POL
8	7.9				Y
9	8.1				Y
10	8.2				Y
11	POL				Y
12	POL				Y
13	POL				Y
14	POL				Y
15	POL				POL
16	POL				POL
17	POL				POL
18	POL				POL
19	8.3				Y
20	POL				POL
21	POL				POL
22	POL				POL
23	POL				POL
24	POL				POL
25	POL				POL
26	POL				POL
27	POL				POL
28	8.4				Y
29					
30					
31					

<<Have minimums been met for this day?

County: Douglas Agency: REGION 2

**ENTRY POINT**  
**EP-A**

**PWS ID 4101092**  
**USFS TILLER RANGER STATION**

Sample period: Feb 2023  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.4

Print Name: Jonathan Woody

Signature: [Signature]

Date & Phone#: 3/3/2023 541-643-6137

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0