

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | 8.3 | | | | Y |
| 2 | pol | | | | pol |
| 3 | 8.2 | | | | Y |
| 4 | POL | | | | POL |
| 5 | POL | | | | POL |
| 6 | pol | | | | pol |
| 7 | pol | | | | pol |
| 8 | pol | | | | pol |
| 9 | 8.0 | | | | Y |
| 10 | 7.8 | | | | Y |
| 11 | 7.8 | | | | Y |
| 12 | POL | | | | POL |
| 13 | pol | | | | pol |
| 14 | pol | | | | pol |
| 15 | pol | | | | pol |
| 16 | pol | | | | pol |
| 17 | pol | | | | pol |
| 18 | 7.8 | | | | Y |
| 19 | POL | | | | POL |
| 20 | pol | | | | pol |
| 21 | pol | | | | pol |
| 22 | pol | | | | pol |
| 23 | POL | | | | POL |
| 24 | pol | | | | pol |
| 25 | 8.0 | | | | YES |
| 26 | POL | | | | POL |
| 27 | pol | | | | pol |
| 28 | pol | | | | pol |
| 29 | pol | | | | pol |
| 30 | pol | | | | pol |
| 31 | | | | | |

<<Have minimums been met for this day?

County: Douglas Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4101092

USFS TILLER RANGER STATION

Sample period: November '23
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.4

Print Name: Jonathan Woody

Signature: Jonathan Woody

Date & Phone#: 12-9-23 5416436137

Send to DWP within 10 days after end of sampling period.

(No = N = Excursion) Total N's 0