

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	Pol				Pol
2	Pol				Pol
3	8.2				Y
4	8.3				Y
5	Pol				Pol
6	8.3				Y
7	Pol				Pol
8	Pol				Pol
9	8.2				Y
10	Pol				Pol
11	Pol				Pol
12	8.0				Y
13	8.1				Y
14	8.3				Y
15	8.2				Y
16	8.2				Y
17	Pol				Pol
18	8.3				Y
19	Pol				Pol
20	8.3				Y
21	8.3				Y
22	8.2				Y
23	8.2				Y
24	Pol				Pol
25	Pol				Pol
26	8.3				Y
27	8.3				Y
28	Pol				Pol
29	Pol				Pol
30	Pol				Pol
31					

<<Have minimums been met for this day? >>

County: Douglas Agency: REGION 2

**ENTRY POINT**

**EP-A**

**PWS ID 4101092**

**USFS TILLER RANGER STATION**

Sample period: April 24  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.4

Print Name: Jonathan Woody

Signature: Jonathan Woody

Date & Phone#: 5-7-24 541-643-6137

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0