

Day	pH	Alk	Phos	Other	Y/N
1	POL				POL
2	POL				POL
3	POL				POL
4	POL				POL
5	8.4				Yes
6	8.4				Y
7	POL				POL
8	POL				POL
9	POL				POL
10	POL				POL
11	POL				POL
12	POL				POL
13	POL				POL
14	POL				POL
15	8.2				Y
16	8.3				Y
17	POL				POL
18	POL				POL
19	POL				POL
20	POL				POL
21	POL				POL
22	POL				POL
23	POL				POL
24	POL				POL
25	8.3				Y
26	8.2				Y
27	POL				POL
28	POL				POL
29	POL				POL
30	POL				POL
31	POL				POL

<<Have
minimums
been met for
this day?

County: Douglas Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4101092

USFS TILLER RANGER STATION

Sample period: January '25
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.4

Print Name: Jonathan Woody

Signature: Jonathan Woody

Date & Phone#: 2-9-25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0