

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.3				Y
2	POL				POL
3	7.7				Y
4	8.0				Y
5	POL				POL
6	POL				POL
7	POL				POL
8	POL				POL
9	POL				POL
10	POL				POL
11	8.4				Y
12	7.9				Y
13	POL				POL
14	POL				POL
15	POL				POL
16	POL				POL
17	POL				POL
18	POL				POL
19	POL				POL
20	8.2				Y
21	8.3				Y
22	POL				POL
23	POL				POL
24	POL				POL
25	POL				POL
26	POL				POL
27	POL				POL
28	POL				POL
29	POL				Y
30	8.4				Y
31					

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

County: Douglas Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4101092

USFS TILLER RANGER STATION

Sample period: April 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.4

Print Name: Jonathan Woody

Signature: John Woody

Date & Phone#: 5-8-25 / 541-643-6137

Send to DWP within 10 days after end of
sampling period