

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	POL				POL
2	POL				POL
3	POL				POL
4	POL				POL
5	8.4				Y
6	8.2				Yes
7	8.3				Yes
8	8.2				Yes
9	POL				POL
10	POL				POL
11	POL				POL
12	POL				POL
13	8.1				Y
14	8.1				Y
15	8.2				Y
16	POL				POL
17	POL				POL
18	8.3				Y
19	8.3				Y
20	8.2				Y
21	POL				POL
22	POL				POL
23	POL				POL
24	POL				POL
25	8.3				Y
26	8.2				Y
27	POL				POL
28	POL				POL
29	8.1				Y
30	7.7				Y
31	POL				POL

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

County: Douglas Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4101092

USFS TILLER RANGER STATION

Sample period: May '25
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH 7.4

Print Name: Jonathan Woody

Signature: [Signature]

Date & Phone#: 6-9-25

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>