

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

★ Day	pH	Alk	Phos	Other	Y/N
1	8.4				Y
2	POL				POL
3	POL				POL
4	POL				POL
5	POL				POL
6	POL				POL
7	POL				POL
8	POL				POL
9	POL				POL
10	8.3				Y
11	8.2				Y
12	POL				POL
13	POL				POL
★ 14	POL	65			POL
15	POL				POL
16	POL				POL
17	POL				POL
18	POL				POL
19	POL				POL
20	POL				POL
21	8.2				Y
22	8.4				Y
23	POL				POL
24	POL				POL
25	POL				POL
26	POL				POL
27	POL				POL
★ 28	POL	60			POL
29	POL				POL
30	POL				POL
31	POL				POL

(No = N = Excursion) Total N's

6

<<Have
minimums
been met for
this day?

County: Douglas Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4101092

USFS TILLER RANGER STATION

Sample period: October 2025
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.4



Print Name: Jonathan Woody

Signature: [Signature]

Date & Phone#: 11-10-25

Send to DWP within 10 days after end of
sampling period