

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH  | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1   | POL |     |      |       | POL |
| 2   | POL |     |      |       | POL |
| 3   | 8.2 |     |      |       | Y   |
| 4   | 8.4 |     |      |       | Y   |
| 5   | POL |     |      |       | POL |
| 6   | POL |     |      |       | POL |
| 7   | POL | 60  |      |       | POL |
| 8   | POL |     |      |       | POL |
| 9   | POL |     |      |       | POL |
| 10  | POL |     |      |       | POL |
| 11  | POL |     |      |       | POL |
| 12  | 8.4 |     |      |       | Y   |
| 13  | 8.1 |     |      |       | Y   |
| 14  | POL |     |      |       | POL |
| 15  | POL |     |      |       | POL |
| 16  | POL |     |      |       | POL |
| 17  | POL |     |      |       | POL |
| 18  | POL |     |      |       | POL |
| 19  | POL |     |      |       | POL |
| 20  | 8.3 |     |      |       | Y   |
| 21  | 8.4 | 60  |      |       | Y   |
| 22  | POL |     |      |       | POL |
| 23  | POL |     |      |       | POL |
| 24  | POL |     |      |       | POL |
| 25  | POL |     |      |       | POL |
| 26  | POL |     |      |       | POL |
| 27  | POL |     |      |       | POL |
| 28  | POL |     |      |       | POL |
| 29  | 8.3 |     |      |       | Y   |
| 30  | 8.2 |     |      |       | Y   |
| 31  |     |     |      |       |     |

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 0 1 0 9 2

System Name: USFS Tiller Ranger Station

Entry Point: WT Plant Sink

Sample Period: November 2025  
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

pH 7.4  
Alk 60 (Alkalinity)  
PO4 (Orthophosphate)  
Other ( )

Print Name: Jonathan Woody

Signature: Jonathan Woody

Date: 12-8-25

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0