

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
RS ³	Admin Sink	8.3				Y

<Has sample met the minimum(s)? County: Douglas Agency: REGION 2
DISTRIBUTION

PWS ID 4101092
USFS TILLER RANGER STATION

Sample Period: March 23
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.4

Print Name: Jonathan Woody
Signature: [Signature]
Date: 4-8-2023

(N = No = Excursion) **Total N's** 0

Send to Drinking Water Program within 10 days after end of sampling period:
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>