

Day	pH	Alk	Phos	Other	Y/N
1	8.5				Y
2	8.3				Y
3	8.1				PO1
4	8.1				PO1
5	8.1				PO1
6	8.1				PO1
7	8.0				Y
8	8.2				Y
9	7.7				Y
10	7.7				Y
11	8.1				PO1
12	8.1				PO1
13	8.1				PO1
14	8.1				PO1
15	8.2				Y
16	8.5				Y
17	8.4				Y
18	8.1				PO1
19	8.1				Y
20	8.1				PO1
21	8.4				Y
22	8.4				Y
23	8.4				Y
24	8.1				PO1
25	8.1				PO1
26	8.1				PO1
27	8.1				PO1
28	8.4				Y
29	8.4				Y
30	8.4				Y
31	8.1				PO1

(No = N = Excursion) Total N's **0**

<<Have minimums been met for this day?

County: Douglas Agency: REGION 2

ENTRY POINT
EP-A
PWS ID 4101092
USFS TILLER RANGER STATION

Sample period: January '22
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

Print Name: John Woody
 Signature: John Woody
 Date & Phone#: 2-8-22

Send to DWP within 10 days after end of sampling period