

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID#	Sample Location	рН	Alk	P04	other	Y/N	<has sample<="" th=""></has>
1	Pump house A	7.2			-		met the minimums?
							PWS ID: 41 0 1 1 2 5
							System Name: MTView CO-op A
							Sample Period:
							Sample Frequency:
8		7.2					Distribution Samples required:
							Number of excursions during this Sample Period =
							(Number of locations when any WQP was less than the minimum.)
							Note: Entry Point and Distribution Excursions are cumulative. Add Entry
15		7.1					Point and Distribution Excursions to get total for sample period.
							For OHA use only
				-			Minimum Water Quality Parameters as set by
22.		7.1					pH 7.1
		-					Alk (Alkalinity) PO4 (Orthophosphate)
							Other ()
29		7.				-	Print Name: Print Name:
	(N = No = Exc		Tot	al N's			Print Name: Ricky white Signature: Ryl. white Date: 1-31-2022

Send to Drinking Water Program within 10 days after end of sampling period: OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/