

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

ID #	Sample Location	pH	Alk	PO4	other	Y/N
5-AUG		7.2				
8-12		7.2				
8-19		7.4				
8-26		7.3				
8-31		7.2				

(N = No = Excursion) Total N's

<Has sample met the minimums?

## DISTRIBUTION

PWS ID: 41 0 1 1 2 5

System Name: MTVIEW CO-OP A

**Sample Period:** Aug 2022

Sample Frequency: weekly *Month/Year*

**Distribution Samples required:**

**Number of excursions during this Sample Period =** \_\_\_\_\_

(Number of locations when any WQP was less than the minimum.)

**Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.**

*-For OHA use only*

### Minimum Water Quality Parameters as set by

pH 7.1

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  ( )

Print Name: RICK WHITE

Signature: Ry 1 White

Date: 8-31-22

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (503) 676-2425, Web: [www.oha.gov](http://www.oha.gov)

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>