

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO ₄	other	Y/N
2-07		7.4				
2-14		7.5				
2-21		7.4				
2-28		7.3				

(N = No = Excursion) Total N's

<Has sample met the minimums?

DISTRIBUTION

PWS ID: 41 0 1 1 2 5

System Name: MTView CO-op A

Sample Period: Feb 2025
Month/Year

Sample Frequency: Weekly Month/Year

Distribution Samples required: 4

Number of excursions during this Sample Period = 4

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

-For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.1

Alk	(Alkalinity)
-----	--------------

PO4 (Orthophosphate)

Other ☐ ()

Print Name: Ricky White

Signature: Ryl-w/te

Date: 03-06-2025

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>