

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.3				Y
7					
8					
9					
10					
11					
12					
13	7.6				Y
14					
15					
16					
17					
18					
19					
20	7.4				Y
21					
22					
23					
24					
25					
26	7.4				Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: CLACKAMAS COUNTY

ENTRY POINT
EP-A

PWS ID 4101125
MOUNTAIN VIEW CO-OP

Sample period: 02/2024
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.1

Print Name: Ricky White
 Signature: R. White 971-378-5330
 Date & Phone#: 03-02-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's