



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2				
2					
3					
4					
5					
6					
7					
8					
9	7.2				
10					
11					
12					
13					
14					
15					
16	7.9				
17					
18					
19					
20					
21					
22					
23	7.3				
24					
25					
26					
27					
28					
29					
30	7.1				
31					

<<Have minimums been met for this day?

County: Clackamas Agency: CLACKAMAS COUNTY

**ENTRY POINT**

**EP-B**

**PWS ID 4101125**

You can only enter numbers or backspace or delete

Sample period: 03/2021  
Month/Year

Number of excursions during this month: \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.1

Print Name: KAREN DANIELSON

Signature: Karen Danielson

Date Phone#: 503-680-4592

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's