



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control



Day	pH	Alk	Phos	SIII	Y/N
1	7.2				
2					
3					
4					
5					
6					
7					
8	7.1				
9					
10					
11					
12					
13					
14					
15	7.2				
16					
17					
18					
19					
20					
21					
22	7.3				
23					
24					
25					
26					
27					
28					
29	7.2				
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: CLACKAMAS COUNTY

ENTRY POINT

EP-B

PWS ID 4101125

You can only enter numbers or backspace or delete

Sample period: 09-1-2021
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.1

Print Name: KAREN DANIELSON

Signature: Karen Danielson

Date Phone#: 503-630-4592

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's