

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14	8.5				Y
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27	8.4				Y
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4101148

Columbia Acres Water Assoc

Sample period: July 2021
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Matt Olson

Signature: 

Date & Phone#: 08-08-2021 503-438-0471

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0