

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.1				
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25	7.2				
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Deer Island Water Works

Entry Point: Hose B/B

Sample Period: July 2022
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other

Print Name: Justin Melville
 Signature: *Justin Melville*
 Date: 8-10-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's