

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.2				
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18	7.2				
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29	7.1				
30					
31					

<<Have  
minimums  
been met for  
this day?

### ENTRY POINT

PWS ID: 41

System Name: Deer Island Waterworks

Entry Point: Test Port # 1

Sample Period: MAY 2025  
Month/Year

Number of excursions\* during this month:             
(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months:             
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

### Minimum Water Quality Parameters as set by

pH  (Alkalinity)  
Alk  (Orthophosphate)  
PO4  (\_\_\_\_\_  
Other

Print Name: Justin McMullen

Signature: Justin McMullen

Date: June. 10th 2025

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's