

Day	pH	Alk	Phos	Other	Y/N
1	7.6		0.6		Yes
2	7.5		0.6		Yes
3	7.5		0.5		Yes
4	7.5		0.5		Yes
5	7.5		0.6		Yes
6	7.5		0.6		Yes
7	7.5		0.6		Yes
8	7.6		0.6		Yes
9	7.6		0.8		Yes
10	7.8		0.8		Yes
11	7.6		0.8		Yes
12	7.6		0.6		Yes
13	7.6		0.6		Yes
14	7.6		0.6		Yes
15	7.6		0.6		Yes
16	7.6		0.6		Yes
17	7.6		0.6		Yes
18	7.6		0.5		Yes
19	7.6		0.5		Yes
20	7.6		0.5		Yes
21	7.6		0.5		Yes
22	7.7		0.6		Yes
23	7.7		0.6		Yes
24	7.5		0.6		Yes
25	7.5		0.6		Yes
26	7.5		0.7		Yes
27	7.5		0.7		Yes
28	7.5		0.7		Yes
29					
30					
31					

<<Have minimums been met for this day?

County: Wasco Agency: REGION 1

**ENTRY POINT**  
**EP-A**  
**PWS ID 4101246**  
**YOUNG LIFE**

Sample period: February 2021  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH

PO4  (Orthophosphate)

Print Name: Bill Palmyres

Signature: W.B. Palmyres

Date & Phone#: 3/10/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's