

Day	pH	Alk	Phos	Other	Y/N
1	7.5		0.4		Yes
2	7.5		0.4		Yes
3	7.5		0.4		Yes
4	7.5		0.4		Yes
5	7.5		0.4		Yes
6	7.5		0.4		Yes
7	7.5		0.4		Yes
8	7.5		0.3		Yes
9	7.5		0.3		Y
10	7.5		0.3		Y
11	7.5		0.4		Y
12	7.5		0.4		Y
13	7.5		0.6		Y
14	7.5		0.3		Y
15	7.4		0.3		Y
16	7.5		0.5		Y
17	7.5		0.5		Y
18	7.5		0.4		Y
19	7.6		0.5		Y
20	7.5		0.4		Y
21	7.5		0.5		Y
22	7.5		0.5		Yes
23	7.5		0.5		Yes
24	7.5		0.6		Y
25	7.7		0.5		Y
26	7.5		0.5		Y
27	7.6		0.6		Y
28	7.7		0.4		Y
29	7.6		0.4		Yes
30	7.6		0.4		Yes
31	7.6		0.4		Yes

<<Have minimums been met for this day?

County: Wasco Agency: REGION 1

ENTRY POINT
EP-A
PWS ID 4101246
YOUNG LIFE

Sample period: May 2021
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

PO4 (Orthophosphate)

Print Name: Bill Palmaymesa

Signature: W.B. Palmaymesa

Date & Phone#: 6/9/2021 (541) 489-3100

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's