

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | 7.6 | | 0.3 | | Y |
| 2 | 7.7 | | 0.3 | | Y |
| 3 | 7.6 | | 0.4 | | Y |
| 4 | 7.6 | | 0.3 | | Y |
| 5 | 7.6 | | 0.3 | | Y |
| 6 | 7.6 | | 0.4 | | Y |
| 7 | 7.6 | | 0.3 | | Y |
| 8 | 7.7 | | 0.3 | | Y |
| 9 | 7.6 | | 0.3 | | Y |
| 10 | 7.7 | | 0.4 | | Y |
| 11 | 7.6 | | 0.3 | | Y |
| 12 | 7.6 | | 0.3 | | Y |
| 13 | 7.6 | | 0.3 | | Y |
| 14 | 7.7 | | 0.4 | | Y |
| 15 | 7.7 | | 0.6 | | Y |
| 16 | 7.7 | | 0.3 | | Y |
| 17 | 7.6 | | 0.3 | | Y |
| 18 | 7.7 | | 0.4 | | Y |
| 19 | 7.7 | | 0.3 | | Y |
| 20 | 7.7 | | 0.3 | | Y |
| 21 | 7.7 | | 0.3 | | Y |
| 22 | 7.7 | | 0.3 | | Y |
| 23 | 7.7 | | 0.3 | | Y |
| 24 | 7.6 | | 0.4 | | Y |
| 25 | 7.6 | | 0.3 | | Y |
| 26 | 7.6 | | 0.3 | | Y |
| 27 | 7.7 | | 0.3 | | Y |
| 28 | 7.6 | | 0.3 | | Y |
| 29 | 7.6 | | 0.3 | | Y |
| 30 | 7.6 | | 0.3 | | Y |
| 31 | 7.5 | | 0.3 | | Y |

<<Have minimums been met for this day?

County: Wasco Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4101246

YOUNG LIFE

Sample period: July / 2022
 Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

PO4 (Orthophosphate)

Print Name: Bill Palmaymesa

Signature: [Signature]

Date & Phone#: 8/7/22 (541) 990-2153

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's