

Day	pH	Alk	Phos	Other	Y/N
1	7.5		0.3		Y
2	7.7		0.3		Y
3	7.6		0.3		Y
4	7.6		0.3		Y
5	7.7		0.3		Y
6	7.7		0.5		Y
7	7.6		0.3		Y
8	7.6		0.3		Y
9	7.6		0.3		Y
10	7.6		0.3		Y
11	7.6		0.3		Y
12	7.6		0.4		Y
13	7.6		0.3		Y
14	7.6		0.3		Y
15	7.6		0.4		Y
16	7.7		0.4		Y
17	7.6		0.3		Y
18	7.5		0.3		Y
19	7.6		0.3		Y
20	7.6		0.5		Y
21	7.6		0.3		Y
22	7.7		0.3		Y
23	7.6		0.3		Y
24	7.6		0.3		Y
25	7.6		0.3		Y
26	7.6		0.4		Y
27	7.6		0.3		Y
28	7.6		0.3		Y
29	7.6		0.4		Y
30	7.6		0.4		Y
31	7.6		0.3		Y

<<Have minimums been met for this day?

County: Wasco Agency: REGION 1

ENTRY POINT
EP-A
PWS ID 4101246
YOUNG LIFE

Sample period: August 2022
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

PO4 (Orthophosphate)

Print Name: Bill Palmyres
 Signature: [Signature]
 Date & Phone#: 9/6/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's