

Day	pH	Alk	Phos	Other	Y/N
1	7.6		0.3		Y
2	7.6		0.3		Y
3	7.7		0.4		Y
4	7.6		0.5		Y
5	7.7		0.5		Y
6	7.6		0.5		Y
7	7.6		0.5		Y
8	7.6		0.6		Y
9	7.6		0.6		Y
10	7.7		0.5		Y
11	7.6		0.4		Y
12	7.6		0.3		Y
13	7.6		0.4		Y
14	7.7		0.4		Y
15	7.7		0.3		Y
16	7.6		0.4		Y
17	7.7		0.4		Y
18	7.7		0.4		Y
19	7.7		0.5		Y
20	7.7		0.4		Y
21	7.7		0.4		Y
22	7.7		0.4		Y
23	7.7		0.4		Y
24	7.7		0.3		Y
25	7.7		0.4		Y
26	7.8		0.4		Y
27	7.7		0.4		Y
28	7.7		0.4		Y
29	7.7		0.5		Y
30	7.8		0.5		Y
31	7.8		0.6		Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Young Life

Entry Point: EP-A

Sample Period: July 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

Minimum Water Quality Parameter(s) as set by State:

pH

PO4 (Orthophosphate)

Print Name: John Gastineau

Signature: 

Date: 8/4/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's