

Day	pH	Alk	Phos	Other	Y/N
1	7.7		.6		Y
2	7.7		.6		Y
3	7.7		.6		Y
4	7.7		.4		Y
5	7.8		.5		Y
6	7.7		.4		Y
7	7.7		.4		Y
8	7.7		.4		Y
9	7.7		.4		Y
10	7.7		.3		Y
11	7.7		.3		Y
12	7.8		.3		Y
13	7.7		.5		Y
14	7.8		.5		Y
15	7.8		.6		Y
16	7.7		.6		Y
17	7.7		.5		Y
18	7.7		.4		Y
19	7.7		.4		Y
20	7.7		.3		Y
21	7.7		.3		Y
22	7.7		.3		Y
23	7.7		.3		Y
24	7.7		.3		Y
25	7.7		.3		Y
26	7.7		.3		Y
27	7.7		.3		Y
28	7.7		.3		Y
29	7.7		.3		Y
30	7.6		.3		Y
31	7.6		.3		Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 0 1 2 4 6

System Name: Young Life

Entry Point: EP-A

Sample Period: August 2023  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference \_\_\_\_\_

Minimum Water Quality Parameter(s) as set by State:

pH 7.3

PO4 0.3 (Orthophosphate)

Print Name: John Gastineau

Signature: 

Date: 9/6/23

Send to DWP within 10 days after end of sampling period