

Day	pH	Alk	Phos	Other	Y/N
1	7.6		0.4		Y
2	7.6		0.5		Y
3	7.6		0.4		Y
4	7.6		0.5		Y
5	7.6		0.4		Y
6	7.6		0.5		Y
7	7.6		0.5		Y
8	7.6		0.5		Y
9	7.6		0.5		Y
10	7.6		0.4		Y
11	7.6		0.4		Y
12	7.6		0.4		Y
13	7.6		0.4		Y
14	7.6		0.5		Y
15	7.6		0.5		Y
16	7.7		0.5		Y
17	7.7		0.5		Y
18	7.6		0.4		Y
19	7.6		0.5		Y
20	7.6		0.5		Y
21	7.6		0.5		Y
22	7.6		0.5		Y
23	7.6		0.4		Y
24	7.7		0.4		Y
25	7.6		0.4		Y
26	7.6		0.4		Y
27	7.6		0.5		Y
28	7.6		0.6		Y
29	7.5		0.4		Y
30	7.6		0.5		Y
31	7.6		0.6		Y

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Young Life

Entry Point: EP-A

Sample Period: March 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

PO4 (Orthophosphate)

Print Name: John Gasteau

Signature: *John Gasteau*

Date: 4/7/24

Send to DWP within 10 days after end of sampling period