

Day	pH	Alk	Phos	Other	Y/N
1	7.6		0.6		Y
2	7.6		0.8		Y
3	7.5		0.9		Y
4	7.5		0.5		Y
5	7.5		0.7		Y
6	7.5		0.5		Y
7	7.5		0.5		Y
8	7.5		0.6		Y
9	7.6		0.6		Y
10	7.5		0.7		Y
11	7.5		0.7		Y
12	7.5		0.7		Y
13	7.6		0.6		Y
14	7.5		0.7		Y
15	7.5		0.6		Y
16	7.5		0.6		Y
17	7.5		0.6		Y
18	7.5		0.7		Y
19	7.5		0.6		Y
20	7.5		0.7		Y
21	7.5		0.6		Y
22	7.5		0.6		Y
23	7.5		0.6		Y
24	7.5		0.7		Y
25	7.6		0.7		Y
26	7.5		0.6		Y
27	7.5		0.6		Y
28	7.5		0.6		Y
29	7.5		0.6		Y
30	7.5		0.7		Y
31	7.5		0.8		Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	1	2	4	6
---	---	---	---	---

System Name: Young Life

Entry Point: EP-A

Sample Period: July 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

Minimum Water Quality Parameter(s) as set by State:

pH

7.3

PO4

0.3

 (Orthophosphate)

Print Name: John Gastineau

Signature: *[Signature]*

Date: 8/9/24

Send to DWP within 10 days after end of sampling period