

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6		0.7		Y
2	7.6		0.8		Y
3	7.5		0.7		Y
4	7.6		0.6		Y
5	7.5		0.5		Y
6	7.5		0.5		Y
7	7.5		0.5		Y
8	7.5		0.5		Y
9	7.5		0.5		Y
10	7.5		0.5		Y
11	7.5		0.5		Y
12	7.5		0.5		Y
13	7.5		0.4		Y
14	7.6		0.8		Y
15	7.5		0.4		Y
16	7.5		0.4		Y
17	7.5		0.5		Y
18	7.5		0.5		Y
19	7.5		0.5		Y
20	7.6		0.5		Y
21	7.5		0.6		Y
22	7.5		0.4		Y
23	7.5		0.4		Y
24	7.5		0.5		Y
25	7.5		0.5		Y
26	7.5		0.5		Y
27	7.5		0.5		Y
28	7.5		0.5		Y
29	7.4		0.5		Y
30	7.6		0.5		Y
31					

<<Have minimums been met for this day?

## ENTRY POINT

PWS ID: 41

0	1	2	4	6
---	---	---	---	---

System Name: Young Life

Entry Point: EP-A

Sample Period: September 2024

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.3

PO4 0.3 (Orthophosphate)

Print Name: John Castineau

Signature: [Signature]

Date: 10/8/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0