

Day	pH	Alk	Phos	Other	Y/N
1	7.7		0.6		Y
2	7.6		0.5		Y
3	7.6		0.5		Y
4	7.7		0.6		Y
5	7.7		0.6		Y
6	7.7		0.5		Y
7	7.7		0.5		Y
8	7.7		0.5		Y
9	7.7		0.4		Y
10	7.7		0.5		Y
11	7.6		0.5		Y
12	7.6		0.5		Y
13	7.7		0.5		Y
14	7.7		0.5		Y
15	7.7		0.6		Y
16	7.7		0.5		Y
17	7.6		0.5		Y
18	7.6		0.5		Y
19	7.7		0.5		Y
20	7.6		0.5		Y
21	7.7		0.5		Y
22	7.6		0.5		Y
23	7.6		0.5		Y
24	7.6		0.5		Y
25	7.6		0.6		Y
26	7.7		0.5		Y
27	7.7		0.5		Y
28	7.7		0.5		Y
29	7.7		0.5		Y
30	7.7		0.5		Y
31	7.7		0.5		Y
(No = N = Excursion) Total N's					0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	1	2	4	6
---	---	---	---	---

System Name: Young Life

Entry Point: EP-A

Sample Period: January 2025

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH 7.3

PO4 0.3 (Orthophosphate)

Print Name: John Gastineau

Signature: [Signature]

Date: 2/5/25

Send to DWP within 10 days after end of
sampling period