

Day	pH	Alk	Phos	Other	Y/N
1	7.6				
2	7.7				
3	7.5				
4	7.6				
5	7.6				
6	7.3				
7	7.5				
8	7.5				
9	7.5				
10	7.5				
11	7.6				
12	7.5				
13	7.4				
14	7.5				
15	7.7				
16	7.3				
17	7.8				
18	7.5				
19	7.5				
20	7.6				
21	7.4				
22	7.4				
23	7.7				
24	7.6				
25	7.5				
26	7.7				
27	7.7				
28	7.6				
29					
30					
31					

<<Have minimums been met for this day?

County: Multnomah Agency: MULTNOMAH COUNTY

**ENTRY POINT
EP-A**

**PWS ID 4101267
MANNA HOUSE CHURCH**

Sample period: February 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Torrie-Lynae Wilson
 Signature: Torrie-Lynae Wilson
 Date & Phone#: 03-01-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's N