

Day	pH	Alk	Phos	Other	Y/N
1	7.6				
2	7.4				
3	7.4				
4	7.5				
5	7.3				
6	7.6				
7	7.4				
8	7.3				
9	7.5				
10	7.5				
11	7.3				
12	7.4				
13	7.6				
14	7.3				
15	7.3				
16	7.4				
17	7.6				
18	7.5				
19	7.5				
20	7.3				
21	7.4				
22	7.3				
23	7.3				
24	7.4				
25	7.6				
26	7.4				
27	7.5				
28	7.5				
29	7.3				
30	7.4				
31	7.3				

<<Have minimums been met for this day?

County: Multnomah Agency: MULTNOMAH COUNTY

**ENTRY POINT**  
**EP-A**  
**PWS ID 4101267**  
**MANNA HOUSE CHURCH**

Sample period: March 2024  
 Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Juliette Marin

Signature: *Juliette Marin*

Date & Phone#: 4/3/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0