

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				
2	7.4				
3	7.4				
4	7.3				
5	7.7				
6	7.9				
7	7.4				
8	7.5				
9	7.2				
10	7.3				
11	7.9				
12	7.6				
13	7.6				
14	7.7				
15	7.5				
16	7.4				
17	7.5				
18	7.9				
19	8.0				
20	7.3				
21	7.4				
22	7.3				
23	7.6				
24	7.7				
25	7.8				
26	7.3				
27	7.2				
28	7.7				
29	7.6				
30	7.4				
31	7.3				

<<Have
minimums
been met for
this day?

County: Multnomah Agency: MULTNOMAH COUNTY

ENTRY POINT

EP-A

PWS ID 4101267

MANNA HOUSE CHURCH

Sample period: 06/2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Eloy Herrera

Signature: Eloy Herrera

Date & Phone#: 6/6/25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0