

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

pH Source

Day	pH	Alk	Phos	Other	Y/N
1	7.6				
2	7.7				
3	7.8				
4	7.4				
5	7.5				
6	7.3				
7	7.9				
8	7.9				
9	7.8				
10	7.4				
11	7.3				
12	7.2				
13	7.9				
14	7.9				
15	7.8				
16	7.3				
17	7.7				
18	7.7				
19	7.5				
20	7.6				
21	7.9				
22	7.4				
23	7.9				
24	7.7				
25	7.5				
26	7.4				
27	7.6				
28	7.7				
29	7.3				
30	7.9				
31	7.5				

<<Have minimums been met for this day?

County: Multnomah Agency: MULTNOMAH COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4101267**

**MANNA HOUSE CHURCH**

Sample period: 6/25  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Eloy Herrera

Signature: Eloy Herrera

Date & Phone#: 7/9/25

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0