

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.5				Y
3	7.6				Y
4	7.6				Y
5	7.6				Y
6	7.7				Y
7	7.7				Y
8	7.5				Y
9	7.6				Y
10	7.7				Y
11	7.6				Y
12	7.6				Y
13	7.7				Y
14	7.7				Y
15	7.7				Y
16	7.7				Y
17	7.6				Y
18	7.6				Y
19	7.7				Y
20	7.7				Y
21	7.7				Y
22	7.7				Y
23	7.7				Y
24	7.6				Y
25	7.6				Y
26	7.6				Y
27	7.7				Y
28	7.7				Y
29	7.7				Y
30	7.7				Y
31	7.7				Y

<<Have minimums been met for this day?

County: Multnomah Agency: MULTNOMAH COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4101267**

**MANNA HOUSE CHURCH**

Sample period: January / 2021  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Kelley Thompson

Signature: [Signature]

Date & Phone#: 1/31/2021 205-999-4366

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0