

# Lead & Copper Rule Corrosion Control

| Day                                 | Sample Location (Other than Entry Point) | pH   | Alk | PO4 | other | Y/N |
|-------------------------------------|--|------|-----|-----|-------|-----|
| 7                                   |  | 7.26 |     |     |       | Y   |
| 21                                  |  | 7.22 |     |     |       | Y   |
|                                     |  |      |     |     |       |     |
|                                     |  |      |     |     |       |     |
|                                     |  |      |     |     |       |     |
| (N = No = Excursion)      Total N's |  |      |     |     |       | 0   |

<Has sample met the minimums? **ENTRY POINT**

PWS ID: 41 0 1 4 6 4

System Name: Hidden Meadows

Sample Period: JULY 2024

Sample Frequency: Every 2 weeks

Entry Point Samples required: 2

Number of excursions during this Sample Period = 0

*(Number of locations when any WQP was less than the minimum.)*

*Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.2

Alk  *(Alkalinity)*

PO4  *(Orthophosphate)*

Other  *(\_\_\_\_\_)*

Print Name: JJ Olson

Signature: *JJ Olson*

Date: 08/10/2024

Send to Drinking Water Program within 10 days after end of sampling period:  
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>