

ID #	Sample Location	pH	Alk	PO4	other	Y/N
8/8/23 SAMPLING:						
2	15574 SE River Forest Dr	7.68	43			N
4	17825 SE River Rd	7.61	43			N
30	19310 SE River Rd	7.71	41			N
12	6313 SE Hull Ave	7.67	39			N
13	5576 SE Viewcrest Dr	7.69	41			N
15	15810 SE McLoughlin Blvd	7.81	39			N
16	13108 SE Briggs St	7.78	43			N
36	12363 SE Whitcomb Dr	7.91	45			Y
17	13240 SE Laurie Ave	7.81	43			N
20	15151 SE Rupert Dr	7.78	43			N
Vv1	Valley View Reservoir	7.68	39			N
8/23/23 SAMPLING:						
2	15574 SE River Forest Dr	7.92	39			Y
4	17825 SE River Rd	7.52	41			N
30	19310 SE River Rd	7.84	45			N
12	6313 SE Hull Ave	7.88	43			N
13	5576 SE Viewcrest Dr	7.86	39			N
15	15810 SE McLoughlin Blvd	7.90	37			Y
16	13108 SE Briggs St	7.74	39			N
36	12363 SE Whitcomb Dr	7.95	43			Y
17	13240 SE Laurie Ave	7.80	39			N
20	15151 SE Rupert Dr	7.87	39			N
Vv1	Valley View Reservoir	7.88	39			N
(N = No = Excursion) Total N's						18

<Has sample met the minimums?

DISTRIBUTION

PWS ID: 4101512

System Name: Oak Lodge Water Services

Sample Period: August 2023

Month/Year

Sample Frequency: every 3 years

Distribution Samples required: 10+EP

Number of excursions during this Sample Period = 18

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.9	
Alk	35.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	(_____)

Print Name: Mandy Gwendler
 Signature: Mandy Gwendler
 Date: 10/9/23

Send to Drinking Water Program within 10 days after end of sampling period:
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>