



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	other	Y/N
	See Attached					
	Excel Sheet					

<Has sample met the minimums? **DISTRIBUTION**

**PWS ID: 41** 0 1 5 1 3

**System Name:** Hillsboro, City of

**Sample Period:** 06/2021 - 09/2021  
Month/Year

**Sample Frequency:** 36 Months

**Distribution Samples required:** 7

**Number of excursions during this Sample Period =** 0  
*(Number of locations when any WQP was less than the minimum.)*

*Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	<span style="border: 1px solid black; padding: 2px 5px;">7.2</span>	
Alk	<span style="border: 1px solid black; padding: 2px 5px;">N/A</span>	<i>(Alkalinity)</i>
PO4	<span style="border: 1px solid black; padding: 2px 5px;">N/A</span>	<i>(Orthophosphate)</i>
Other	<span style="border: 1px solid black; padding: 2px 5px;">N/A</span>	<i>(_____)</i>

**Print Name:** Sarah Honious

**Signature:** *Sarah Honious*

**Date:** 10/26/2021

(N = No = Excursion)      **Total N's**      0

Send to Drinking Water Program within 10 days after end of sampling period:  
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405    Website: <http://healthoregon.org/dwp/>

Row Labels	Number of Measurements	Average pH	Max pH	Min pH
1340 SE 70th Ave	5	8.15	8.51	8.01
15th & Griffen Oaks	4	7.95	8.3	7.48
1776 NE Grant St	4	8.15	8.53	7.93
1954 SE 54th Ave	8	7.96	8.21	7.88
21st & TV Hwy	7	7.85	7.93	7.71
2218 Meadowlark Dr	6	7.76	8.07	7.5
2450 SE 72nd Ave	5	8.02	8.21	7.84
24th St. Reservoir	20	7.88	8.03	7.6
2650 Singing Woods Dr	8	8.08	8.24	8
4180 SE Bently Rd	12	7.98	8.29	7.9
4244 SE Wynnwood Dr	12	7.91	8.18	7.64
5800 SE Alexander	4	7.55	7.8	7.34
58th Court & Patterson	8	8.10	8.7	7.94
6122 SE Hacienda St	8	8.07	8.38	7.94
6164 SE Hieke St	4	7.97	8.28	7.79
64th Ct & Olerich Rd	4	8.14	8.38	8.04
67th & Alexander	16	7.79	8.14	7.58
927 SE Cedar	8	7.89	8.2	7.59
Bagley Park	9	7.92	8.11	7.85
Blanton PRV	15	7.82	8.12	7.76
Brookwood & NE Airport Rd	5	8.11	8.41	7.9
Century & Bennett	14	7.83	8.23	7.44
Century & Evergreen	8	7.88	8.23	7.59
Crandall Reservoir	19	8.01	8.18	7.54
Evergreen & 25th	5	7.74	8.02	7.6
Evergreen & Dawson Ck	8	7.75	7.97	7.53
Evergreen & Glencoe	5	7.73	8.04	7.35
Evergreen Reservoir	19	7.90	8.05	7.83
Jackson Sch & Sundance Ct	5	7.98	8.18	7.85
Merle & Glencoe	4	7.95	8.14	7.73
NE 10th Ave & NE Lilac Ct	7	7.93	8.09	7.77
NE 10th Ave & NE Simmental St	9	8.02	8.39	7.72
NE 37th Ave & NE Olympic St	8	8.08	8.16	7.93
NE 53rd Ave North of Baseline Rd	4	7.99	8.31	7.58
NE Aurora Dr E of NE Zander Ct	4	7.77	7.93	7.68
NE Birchaire Ln & NE Hawthorne Ave	4	8.20	8.45	7.98
NE Birchwood Dr & NE Birchwood Ln	8	7.93	8.09	7.74
NE Butler Rd West of NE 65th Ave	8	7.78	8.18	7.54
NE Geraldine Dr & NE Goldie Dr	8	8.10	8.72	7.84
NE Shaleen St & Nelly St	6	8.47	8.78	8.29
NE Stile Rd & NE Ray Circle	12	8.14	8.29	7.89
NW 10th & 8th Dr	9	8.16	8.35	8.03
NW Jackson & Connell	7	7.92	8.14	7.68
NW Quatama & 227th Ave	8	8.14	8.43	7.9

River Rd & Witch Hazel	6	8.13	8.39	7.68
SE 13th Ave & SE Cedar St	9	8.01	8.45	7.8
SE 24th & SE Maple St	8	7.84	7.93	7.66
SE 34th Ct & SE Oak St	7	8.13	8.26	8.06
SE 36th Ave & SE Willow	7	7.98	8.04	7.88
SE 3rd St and SE Maple St	15	7.68	8.15	7.5
SE 41st Ave & SE Russel St	8	8.25	8.41	8.13
SE 5th Ave & SE Washington	4	7.93	8.02	7.82
SE 68th & SE Borwick Rd	7	8.16	8.32	8.06
SE Anthony & Minter Br Rd	13	7.78	8.05	7.54
SE Provance and SE Polyanta	5	7.90	8.12	7.57
SE Rosewood and SE Oakhurst St	4	7.97	8.1	7.85
SE Tamora Ave & Roundelay St	8	8.05	8.48	7.96
SE Wenlock and SE Tomango	5	8.01	8.33	7.87
<b>Grand Total</b>	<b>467</b>	<b>7.95</b>	<b>8.78</b>	<b>7.34</b>