

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	Sample Location (Other than Entry Point)	рН	Alk	PO4	other	Y/N	<has sample<="" th=""></has>
2		7.4				Y	met the ENTRY POINT - B
11		7.4				Y	minimums? (Snider)
19		7.4				Y	PWS ID: 41 0 1 5 1 8
26		7.0				Y	System Name: Chehalem Springs
							Sample Period: <u>February 2023</u>
							Number of excursions during this Sample Period = 0
	(N = No = Excu	rsion)	To	tal N'	s	0	(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only							
Minimum Water Quality Parameters as set by							
pH 7.0							
Alk	(Alkalinity)						
PO4	(Orthophosphate)						
Other	()						

Print Name: JJ Olson
Signature: Jeffrey Olson

Date: 03/07/2023

Send to Drinking Water Program within 10 days after end of sampling period: OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/