

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
6		7.4				Y
13		7.4				Y
20		7.4				Y
27		7.3				Y
(N = No = Excursion) <b>Total N's</b>						0

<Has sample met the minimums?  
**ENTRY POINT - B (Snider)**  
**PWS ID: 41** 0 1 5 1 8  
**System Name:** Chehalem Springs  
**Sample Period:** December 2023  
  
**Number of excursions during this Sample Period =** 0

*(Number of locations when any WQP was less than the minimum.)*

*Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.0

Alk  *(Alkalinity)*

PO4  *(Orthophosphate)*

Other  *(\_\_\_\_\_)*

**Print Name:** JJ Olson  
**Signature:** *Jeffrey Olson*  
**Date:** 01/09/2024

Send to Drinking Water Program within 10 days after end of sampling period:  
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>