

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
3		7.31				Y
17		7.29				Y
31		7.14				Y

(N = No = Excursion)

Total N's

0

<Has sample
met the
minimums?

**ENTRY POINT - B
(Snider)**

PWS ID: 41 **0 1 5 1 8**

System Name: Chehalem Springs

Sample Period: OCT 2025

Number of excursions during this
Sample Period = 0

(Number of locations when any WQP
was less than the minimum.)

*Note: Entry Point and Distribution
Excursions are cumulative. Add Entry
Point and Distribution Excursions to get
total for sample period.*

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.0
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	(_____)

Print Name: Curtis Olson

Signature: Curtis Olson

Date: 11/10/2025

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>