

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

| Day | Sample Location (Other than Entry Point) | pH | Alk | PO4 | other | Y/N |
|-------------------------------------|--|-----|-----|-----|-------|-----|
| 5 | | 7.1 | | | | Y |
| 12 | | 6.9 | | | | Y |
| 19 | | 6.9 | | | | Y |
| 26 | | 7.1 | | | | Y |
| (N = No = Excursion) Total N's | | | | | | 0 |

<Has sample met the minimums?

ENTRY POINT

PWS ID: 41 0 1 5 1 9

System Name: Chehalem – Oliver

Sample Period: January 2024

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by

| | | |
|-------|-----|------------------|
| pH | 6.9 | |
| Alk | | (Alkalinity) |
| PO4 | | (Orthophosphate) |
| Other | | (_____) |

Print Name: JJ Olson

Signature: *Jeffrey Olson*

Date: 02/09/2024

Send to Drinking Water Program within 10 days after end of sampling period:
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>