

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
7		7.2				Y
14		7.0				Y
21		7.5				Y
28		7.9				Y
(N = No = Excursion) <b>Total N's</b>						0

<Has sample met the minimums?      **ENTRY POINT**

**PWS ID: 41** 0 1 5 1 9

**System Name:** Chehalem – Oliver

**Sample Period:** June 2024

**Number of excursions during this Sample Period =** 0

*(Number of locations when any WQP was less than the minimum.)*


*Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	6.9	
Alk		<i>(Alkalinity)</i>
PO4		<i>(Orthophosphate)</i>
Other		<i>(_____)</i>

**Print Name:** JJ Olson

**Signature:** 

**Date:** 07/09/2024

Send to Drinking Water Program within 10 days after end of sampling period:  
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405    Website: <http://healthoregon.org/dwp/>