

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: January 2021

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
01/01/2021	7.93	22.5	Yes
01/02/2021	7.91	24.5	Yes
01/03/2021	7.85	21.5	Yes
01/04/2021	7.89	19.0	Yes
01/05/2021	7.95	14.5	Yes
01/06/2021	7.92	18.0	Yes
01/07/2021	7.86	23.5	Yes
01/08/2021	7.83	16.0	Yes
01/09/2021	7.89	21.5	Yes
01/10/2021	7.91	20.5	Yes
01/11/2021	7.95	21.0	Yes
01/12/2021	7.96	22.0	Yes
01/13/2021	7.95	22.0	Yes
01/14/2021	8.02	17.5	Yes
01/15/2021	8.00	20.0	Yes
01/16/2021	7.92	18.0	Yes
01/17/2021	7.92	20.5	Yes
01/18/2021	8.03	21.0	Yes
01/19/2021	7.93	22.0	Yes
01/20/2021	7.91	21.0	Yes
01/21/2021	7.89	23.5	Yes
01/22/2021	7.86	22.5	Yes
01/23/2021	7.81	22.5	Yes
01/24/2021	7.84	24.0	Yes
01/25/2021	7.84	23.5	Yes
01/26/2021	7.83	22.5	Yes
01/27/2021	7.89	23.5	Yes
01/28/2021	7.88	24.0	Yes
01/29/2021	7.86	25.0	Yes
01/30/2021	7.87	25.0	Yes
01/31/2021	7.87	23.5	Yes

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance?

Y/N

Supervisor's Signature Bret Bienerth

Print Name Bret Bienerth

Certification #: 08749

Phone (503) 635-0394

02-Feb-21