

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form  
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: February 2021

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
02/01/2021	7.81	24.0	Yes
02/02/2021	7.82	24.5	Yes
02/03/2021	7.81	25.0	Yes
02/04/2021	7.88	24.5	Yes
02/05/2021	7.84	24.0	Yes
02/06/2021	7.86	24.0	Yes
02/07/2021	7.86	23.5	Yes
02/08/2021	7.85	22.5	Yes
02/09/2021	7.83	23.0	Yes
02/10/2021	7.83	21.0	Yes
02/11/2021	7.86	24.0	Yes
02/12/2021	7.82	23.0	Yes
02/13/2021			
02/14/2021			
02/15/2021	7.88	22.0	Yes
02/16/2021	7.84	21.7	Yes
02/17/2021	7.85	22.0	Yes
02/18/2021	7.83	20.0	Yes
02/19/2021	7.83	20.0	Yes
02/20/2021	7.87	20.0	Yes
02/21/2021	7.90	20.0	Yes
02/22/2021	7.88	20.5	Yes
02/23/2021	7.88	20.0	Yes
02/24/2021	7.87	20.0	Yes
02/25/2021	7.86	21.0	Yes
02/26/2021	7.86	20.3	Yes
02/27/2021	7.89	20.5	Yes
02/28/2021	7.83	21.0	Yes

Number of excursions this month = 0  
Number of excursions last 5 months = 0

Is System in Compliance?

Y/N

Supervisor's Signature

*Bret Bienerth*

Print Name

Bret Bienerth

Certification #:

08749

Phone (503) 635-0394

04-Mar-21