

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: March 2021

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
03/01/2021	7.82	21.5	Yes
03/02/2021	7.88	21.5	Yes
03/03/2021	7.84	23.7	Yes
03/04/2021	7.86	23.5	Yes
03/05/2021	7.85	23.5	Yes
03/06/2021	7.81	23.0	Yes
03/07/2021	7.91	22.5	Yes
03/08/2021	7.92	22.5	Yes
03/09/2021	7.93	23.0	Yes
03/10/2021	7.87	22.0	Yes
03/11/2021	7.88	23.0	Yes
03/12/2021	7.87	23.3	Yes
03/13/2021	7.86	23.0	Yes
03/14/2021	7.82	23.5	Yes
03/15/2021	7.98	25.0	Yes
03/16/2021	7.90	24.5	Yes
03/17/2021	7.92	24.0	Yes
03/18/2021	7.85	24.0	Yes
03/19/2021	7.89	25.0	Yes
03/20/2021	7.88	23.0	Yes
03/21/2021	7.89	24.5	Yes
03/22/2021	7.94	23.5	Yes
03/23/2021	7.94	23.0	Yes
03/24/2021	7.91	23.0	Yes
03/25/2021	7.96	23.0	Yes
03/26/2021	7.91	22.5	Yes
03/27/2021	7.86	22.5	Yes
03/28/2021	7.78	22.0	Yes
03/29/2021	7.87	22.0	Yes
03/30/2021	7.93	22.5	Yes
03/31/2021	7.93	23.5	Yes

Number of excursions this month = 0
Number of excursions last 5 months = 0

Is System in Compliance? Y N

Supervisor's Signature Bret Bienerth Print Name Bret Bienerth

Certification #: 08749 Phone (503) 635-0394 01-Apr-21